



ADDENDUM NUMBER NO. 2

RFP18-065 DUDLEY LANE SIDEWALK PROJECT

PROPOSALS DUE:

MAY 3, 2018 NO LATER THAN 2:00 P.M., EST

COMPLETE THIS ADDENDUM, SIGN and SUBMIT with the RFP.

Questions/Answers:

Question 1: Does the line item for decorative driveways include cost of concrete base layer?

Answer: No, concrete base layer for decorative driveways is to be paid from Line Item 441-0016 Driveway Concrete 6" Thick and 441-4020 Concrete Valley Gutter 6".

Question 2: Sheet 5-01 – Please clarify limits of asphalt patch shown on typical sections.

Answer: Sheet 5-01 has been revised to include a pavement widening detail. The contractor shall maintain at all times a minimum 10'-6" travel lane in areas that require new curb and gutter. The intention of the plans is for the "WIDTH OF EXCAVATED AREA" to be 0'-0" typical. The limits of any "CLASS "B" CONCRETE PAVEMENT WIDENING" shall be approved by the City upon initial layout of the project and prior to any saw cutting of the asphalt. Saw cutting is included in the Grading Complete Pay Item. Quantities for Pay item 500-9999 Class B Concrete and PI# 402-3103 for Recycled Asphalt Concrete 9.5 MM are approximate quantities and are to be as directed by the City Engineer.

Question 3: Will the contract be awarded based on the base bud amount or the base bid amount and the alternate amount?

Answer: The contract will be awarded based on the combined Base Bid and Bid Alternate #1 amounts.

Question 4: This project has a lot of detail. Is the 150 days for just the base bid items or does it include the alternate items as well?

Answer: The 150-day performance period includes the both the Base Bid and Bid Alternate #1.

Questions 5: Where should bids be delivered? The City of Sandy Springs is moving, will this affected the location to where bids should be submitted?

Answer: The City of Sandy Springs will be moving after May 4, 2018. Bidders will be able to drop off their bids on May 3, 2018 at 2:00 p.m.

I hereby acknowledge receipt of Addendum Number 2 for #18-065 Dudley Lane Sidewalk Project and have incorporated the changes into my response for the abovementioned Request for Proposal.

COMPANY NAME: _____

CONTACT PERSON: _____

ADDRESS: _____

CITY: _____ STATE: _____ ZIP: _____

PHONE: _____ FAX: _____ EMAIL ADDRESS: _____

SIGNATURE: _____ DATE: _____

End of Addendum No.2